


VESDA DESIGNATION LEGEND

PIPE 1 ← VESDA PIPE REFERENCE NUMBER  
SECTION 1.1.1-1  
HOLE REFERENCE NUMBER  
VESDA PIPE SECTION REFERENCE NUMBER

- HSSD SAMPLE PIPING AND SAMPLE PORT (BELOW CEILING)
- HSSD SAMPLE PIPING AND SAMPLE PORT (ABOVE CEILING)
- FIRE ALARM CONDUIT (3/4-INCH).  
SEE NOTES PROVIDED ON EACH PLAN FOR CIRCUITS.
- L1 - 1 PAIR #16; SLC/ALD LOOP (L1)  
(SEE RACEWAY NOTES ON EACH FLOOR PLAN)
- AV1 - 1 PAIR #14; NOTIFICATION APPLIANCE CIRCUIT  
(SEE RACEWAY NOTES ON EACH FLOOR PLAN)

HSSD PIPING LAYOUT - FLOOR 2

SCALE: 1/8" = 1'-0"



PROFESSIONAL SEAL (IF REVISION, APPLIES ONLY TO REVISED WORK)	AS BUILT — 08/28/13								74 FIRE ALARM SYSTEM 2ND FLOOR HSSD PIPING PLAN	DRAWN BY	DSV	DATE	08/28/13
										CHECKED BY	LDD	09/03/2013	
										APPROVED BY	MCD	09/03/2013	
										SCALE AS NOTED			
										DRAWING NO. 4B74E317			
									UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY FACILITIES DIVISION		SHEET		
		—	DSV	LDD	MCD	08/28/13	AS BUILT FROM A/E RECORD DWGS					PROJECT NO. FN9200	16 OF 20
	ISSUE	(PROGRESS, ESTIMATE, BID, CONSTRUCTION, CONFORMED, REVISION, RECORD)	REVISION NUMBER	DRAWN BY	CHECKED BY	APPR'D BY	DATE	REMARKS					

UNIVERSITY OF CALIFORNIA  
LAWRENCE BERKELEY NATIONAL LABORATORY  
FACILITIES DIVISION